

# CERRO COPPER & BRASS COMPANY

DIVISION OF CERRO CORPORATION

## INTERNAL MEMORANDUM

Form HQ-10

SHOW NAME, TITLE AND CORPORATION OF ADDRESSEE AND ADDRESSOR

OTHER ADDRESSEES - FOR INFORMATION

CC: P. Tandler  
J. W. Goldenberg  
File 4000

1104

154051

TO: Al Suhre

DATE: September 23, 1970

FROM: Bill Graff

SUBJECT:

I had promised the Monsanto Biodize Engineer, Jerry Jones, that the lift station would be operating properly for their tests starting today based on assurance from Roy Thompson that the station was all set.

When we inspected the unit this afternoon, we found one pump running, the second one off and the sewage overflowing at the 399 ft. elevation which is really only for emergency overflow. The third pump has been out of service for several months for lack of parts according to Dale Graff. I believe packing is the requirement, and if this is the case, I don't see why it takes months to get parts for this equipment.

I don't think we should call in outside assistance just yet, but after we get the 3rd pump repaired, I feel we should ask Horner & Shifrin to check it out.

BG/as

Bill Graff

C03378